

MUNICIPAL CORPORATION SHIMLA
(Health Dept.)

Daily water testing Report - m.c. 20-02-2016.

Sr. no	Dated	Name and place of Sample	Coli-form Per no ml	Residual Chlorine.
1.	20.2.16	Lakshar Bazar	M/L	0.5 ppm
2.	"	Snowdown Bump House	M/L	2.0 ppm
3.	"	Sanjauli Gulel - Guma	M/L	M/L
4.	"	Sanjauli Gulel - Gisi	M/L	M/L
5.	"	Sanjauli Chaula	M/L	2.0 ppm
6.	"	Goresener's House	M/L	1.0 ppm
7.	"	Marins field	M/L	1.0 ppm
8.	"	Bes school	M/L	0.4 ppm
9.	"	Dhiman Bhawan Bawan (Near Bes school)	10 MPN	M/L
10.	"	Must chamber khalini	M/L	1.0 ppm
11.	"	Shalesala supply Tank	M/L	2.0 ppm
12.	"	Kammpati Reservoir	M/L	2.0 ppm
13.	"	Chotta Shimla	M/L	0.8 ppm
14.	"	Ridge	M/L	2.0 ppm
15.	"	Lab - Taps	M/L	2.0 ppm

No. mes/cow/2016-280 Dated 23/2/16 ^{Janak} ~~Sr. Tech.~~

1. Humble Mayor, m.c. Shimla for information please.
2. Humble Dy. Mayor, m.c. Shimla for information please.
3. Commissioner, m.c. Shimla for information please.
4. C.M.O Distt. Shimla for information please.
5. D.H.S. Govt. of H.P. Shimla for information please.
6. Engineer in Chief I.P.H. Shimla for information please.
7. M.E, m.c. Shimla for information and M/L please.
8. I/T ic cell
9. Notice Board
10. office copy

Corporation Health Officer,
Municipal Corporation Shimla