

Pl. upload it

Comp. Assn

5/2/16

MUNICIPAL CORPORATION SHIMLA  
(Health Dept.)

Daily water testing Report - on dt. 02-02-2016.

<u>Sr. No</u>	<u>Dated</u>	<u>Name and Place of Sample</u>	<u>Coli-Form PER 100ml</u>	<u>Residual Chlorine</u>
1.	2-2-16	Ridge	Nil	2.0 PPM
2.	"	Bhagga Niwas	Nil	1.0 PPM
3.	"	Mayan field	Nil	0.5 PPM
4.	"	Kasumpti Reservoir	Nil	2.0 PPM +
5.	"	Sanjauli Gulet-Guma	Nil	0.2 PPM
6.	"	Sanjauli Chouck	Nil	1.0 PPM
7.	"	Dhali Chouck	Nil	2.0 PPM +
8.	"	Dhali Police Station	Nil	1.0 PPM
9.	"	I.S. Pump House	Nil	1.0 PPM
10.	"	Lakkar Bazar	Nil	2.0 PPM
11.	"	Lab. Taps	Nil	2.0 PPM

No. mes/CMO/2016-166

Dated 5/2/16

J. Singh  
Sr. Tech. P.