

MUNICIPAL CORPORATION SHIMLA
(Health Dept.)

Daily water testing Report - on 16-02-2016.

Sr. No	Dated	Name and place of Sample	Coli form Per 100 ml	Residual Chlorine
1.	16-2-16	Ridge	MIL	2.0 ppm+
2.	"	Bhagga Niwas	MIL	2.0 ppm
3.	"	Mains field	MIL	2.0 ppm
4.	"	Kasumpti Reservoir	MIL	2.0 ppm+
5.	"	Shakrals supply Taule	MIL	2.0 ppm+
6.	"	Soni Mehali	MIL	2.0 ppm+
7.	"	Mehali	MIL	2.0 ppm+
8.	"	New Shimla	MIL	2.0 ppm+
9.	"	Sanjauli Gori Gulet-	MIL	MIL
10.	"	Sanjauli Guma Gulet-	MIL	MIL
11.	"	Kasumpti Chouke	MIL	2.0 ppm+
12.	"	Sanjauli Chouke	MIL	2.0 ppm+
13.	"	Snowdown Pump House	MIL	1.0 ppm
14.	"	Lakkar Bazar	MIL	2.0 ppm
15.	"	Lab. Tap	MIL	2.0 ppm

No: mes/CHO/2016-258

Dated 19/2/16

Janki Sr. Tech.

1. Humble mayar, M.C. Shimla for information please.
2. Humble by mayar, M.C. Shimla for information please.
3. Commissioner, M.C. Shimla for information please.
4. C.M.O Distt. Shimla for information please.
5. D.H.S. Govt. of H.P. Shimla for information please.
6. Engineer in Chief I.P.H. Shimla for information please.
7. M.G, M.C. Shimla for information and file please.
8. I/T/I/C cell.
9. Notice Board
10. Office copy.

Corporation Health officer,
Municipal Corporation Shimla.