

SHIMLA MUNICIPAL CORPORATION
(HEALTH DEPARTMENT)

NO.MCS/CHO/2016- 456

DATED: 15/3/16

REPORT OF WATER SAMPLES COLLECTED ON 10-03-2016.

S.No.	Location of samples collected	Coliforms	Residual Chlorine
1	Ridge	M/L	2.0 PPM
2	sect. 3 New Shimla	M/L	3.0 PPM
3	Sanyauli Inlet - Gurga	M/L	3.0 PPM
4	Sanyauli Inlet - Gini	M/L	1.0 PPM
5	Sanyauli Reservoir	M/L	2.0 PPM
6	New Shimla M.C. office	M/L	1.0 PPM
7	B.C.S	M/L	1.0 PPM
8	Carb. Taps	M/L	2.0 PPM

Note: 1. No coliform should be detectable in 100ml of water.
2. Normal Range of residual chlorine is 0.2-2.0PPM.

Copy to:-

1. The Hon'ble Mayor, MC, Shimla.
2. The Hon'ble Dy. Mayor, MC, Shimla.
3. The Commissioner, MC, Shimla.
4. The Director, Health Services, HP, Shimla.
5. Engineer -in-Chief, IPH, HP, Shimla.
6. The Chief Medical Officer, Distt. Shimla, Shimla.
7. The Municipal Engineer, WS&SD, MC, Shimla
8. IT Cell, MC, Shimla for uploading on official website of Municipal Corporation, Shimla.
9. Office copy.

Signature of Sr. Lab Technician

Corporation Health Officer,
MC, Shimla