

SHIMLA MUNICIPAL CORPORATION
(HEALTH DEPARTMENT)


NO.MCS/CHO/2016- 484

DATED: 18/3/16

REPORT OF WATER SAMPLES COLLECTED ON 12-03-2016.


S.No.	Location of samples collected	Coliforms Result	Residual Chlorine Result
1	Ridge Tapwater	NIL	2.0 PPM
2	Sanjauli Reservoir outlet	NIL	2.0 PPM
3	Sanjauli Inlet-Guma	NIL	0.5 PPM
4	Kasumpti Channel	NIL	2.0 PPM
5	Kasumpti Reservoir	NIL	3.0 PPM
6	Shivpuri Tank	NIL	2.0 PPM
7	Shivpuri Tapwater	NIL	1.0 PPM
8	Lab-Taps	NIL	2.0 PPM

Note: 1. No coliform should be detectable in 100ml of water.
2. Range of residual chlorine 0.2-2.0PPM.


Signature of Sr. Lab Technician

Copy to:-

1. The Hon'ble Mayor, MC, Shimla.
2. The Hon'ble Dy. Mayor, MC, Shimla.
3. The Commissioner, MC, Shimla.
4. The Director, Health Services, HP, Shimla.
5. Engineer -in-Chief, IPH, HP, Shimla.
6. The Chief Medical Officer, Distt. Shimla, Shimla.
7. The Municipal Engineer, WS&SD, MC, Shimla
8. IT Cell, MC, Shimla for uploading on official website of Municipal Corporation, Shimla.
9. Office copy.


Corporation Health Officer,
MC, Shimla