

**SHIMLA MUNICIPAL CORPORATION**  
(HEALTH DEPARTMENT)


NO.MCS/CHO/2016- 486

DATED: 18/3/16

REPORT OF WATER SAMPLES COLLECTED ON 14-03-16.

S.No.	Location of samples collected	Coliforms Result	Residual Chlorine Result
1	Ridge	Mi/c	1.00ppm
2	Banjawali Reservoir	Mi/c	1.00ppm
3	Kasumpti Creek	Mi/c	1.00ppm
4	Mains field	Mi/c	2.00ppm
5	Mains field	Mi/c	2.00ppm
6	Bane nose	Mi/c	2.00ppm
7	Banjawali Inlet-Dams	Mi/c	0.20ppm
8	Lab. Tap	Mi/c	1.00ppm


Note: 1. No coliform should be detectable in 100ml of water.  
2. Range of residual chlorine 0.2-2.0PPM.



Signature of Sr. Lab Technician

Copy to:-

1. The Hon'ble Mayor, MC, Shimla.
2. The Hon'ble Dy. Mayor, MC, Shimla.
3. The Commissioner, MC, Shimla.
4. The Director, Health Services, HP, Shimla.
5. Engineer -in-Chief, IPH, HP, Shimla.
6. The Chief Medical Officer, Distt. Shimla, Shimla.
7. The Municipal Engineer, WS&SD, MC, Shimla
8. IT Cell, MC, Shimla for uploading on official website of Municipal Corporation, Shimla.
9. Office copy.

  
Corporation Health Officer,  
MC, Shimla