

Water samples tested in Department of Microbiology IGMC, Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	DCC	Reported on	Result
1066	26-Jul	Samples received from Corporate Health Officer, Municipal Corporation Shimla, Shimla (H.P)	1	lab tap MC shimla	-	Added	0	-	29-Jul	Excellent
1067			2	kali bari tapwater	-	Added	0	-		Excellent
1068			3	Kasumpti Reservoir	-	Added	1	-	29-Jul	Satisfactory
1069			4	clear water tank WTP koti braindi nala	-	Added	25	-		Unsatisfactory
1070			5	kawolg public tap	-	Added	0	-		Excellent
1071			6	mains field tank	-	Added	1	-	29-Jul	Satisfactory
1072			7	sanjauli reservoir outlet	-	Added	11	-	29-Jul	Unsatisfactory
1073	27-Jul	Samples received from Corporate Health Officer, Municipal Corporation Shimla, Shimla (H.P)	1	kanlog public tap	-	Added	0	-	29-Jul	Excellent
1074			2	kasumpti reservoir	-	Added	1	-		Satisfactory
1075			3	sanjauli inlet giri	-	Added	0	-		Excellent
1076			4	sanjauli inlet gumma	-	Added	1	-		Satisfactory
1077			5	norrth oak u.g tank	-	Added	0	-		Excellent