

Water samples tested in Department of Microbiology IGMC, Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	DCC	Reported on	Result
3674	22-Sep	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	sanjauli reservior outlet	-	added	0	-	24-Sep	Excellent
3675			2	engeneer ghar tank	-	added	3	-	24-Sep	Satisfactory
3676			3	bangala colony tank	-	added	0	-	24-Sep	Excellent
3677			4	public tap bangala colony	-	added	1	-	24-Sep	Satisfactory
3678			5	public tap mehta niwas engine ghar	-	added	1	-	24-Sep	Satisfactory
3679			6	kasumpti reservior	-	added	0	-	24-Sep	Excellent
3680	23-Sep	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Fingask Tank No. 1 (B)	-	added	0	-	25-Sep	Excellent
3681			2	fingask tank no. 2	-	added	1	-	26-Sep	satisfactory
3682			3	supply baljees factory fingask	-	added	11	-	25-Sep	unsatisfactory
3683			4	public tap kali bari mandir	-	added		-	25-Sep	Excellent
3684			5	kasumpti reservior	-	added		-	25-Sep	Excellent
3685			6	sanjauli rservior outlet	-	added	35	-	25-Sep	unsatisfactory
3686	24-Sep	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Mainsfield Tank No I outlet	-	added	0	-	26-Sep	Excellent
3687			2	Mainsfield Tank No II outlet	-	added	0	-	26-Sep	Excellent
3688			3	Tap water Raj Bhawan Kitchen	-	added	0	-	26-Sep	Excellent
3689			4	HP Sectt. Old Tank Raj Bhawan	-	added	0	-	26-Sep	Excellent
3690			5	Kasumpati Reservoir	-	added	0	-	26-Sep	Excellent
3691			6	Sanjauli Reservoir Outlet	-	added	0	-	26-Sep	Excellent

3692	25-Sep	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	public tap chotta shimla chowk	-	added	0	-	27-Sep	Excellent
3693			2	kno;;os wood tank	-	added	0	-	27-Sep	Excellent
3694			3	public tap khalini chowk	-	added	0	-	27-Sep	Excellent
3695			4	public tap khalini bypass	-	added	0	-	27-Sep	Excellent
3696			5	kasumpti reservior	-	added	0	-	27-Sep	Excellent
3697			6	sanjauli reservior outlet	-	added	0	-	27-Sep	Excellent