

Water samples tested in Department of Microbiology IGMC, Shimla since 1st Jan 2016

Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	thiosulph	PCC	Final report (72Hrs)	Report ed on	Result
2697	30/Sep	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Dhalli Filter	added	MPN=0		2/Oct	Excellent
2698			2	Sanjauli Tank Inlet from Gumma	added	MPN=0		2/Oct	Excellent
2699			3	Sanjauli Tank Inlet from Giri	added	MPN=0		2/Oct	Excellent
2700			4	Sanjauli Reservoir	added	MPN=0		2/Oct	Excellent
2701			5	Kasumpti Reservoir	added	MPN=0		2/Oct	Excellent
2702			6	P.Tap, Joshi cottage, Shivpuri	added	MPN=0		2/Oct	Excellent
2703			7	P.Tap, Krishna cottage , Shivpuri	added	MPN=0		2/Oct	Excellent
2704			8	Shivpuri Tank	added	MPN=0		2/Oct	Excellent

2705	1/Oct	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	P.tap, Ridge	added	MPN=0		3/Oct	EXCELLENT
2706			2	P.tap, Radha Swami Satsang, Lakkar Bazar	added	MPN=0		3/Oct	EXCELLENT
2707			3	Dhingoo mandir tank (lower)	added	MPN=180+		3/Oct	UNSATISFACTORY
2708			4	Dhingoo mandir tank (upper)	added	MPN=5		3/Oct	in process
2709			5	Sanjauli tank inlet from GUMMA	added	MPN=0		3/Oct	EXCELLENT
2710			6	Sanjauli tank inlet from GIRI	added	MPN=1		3/Oct	in process
2711			7	Sanjauli reservoir	added	MPN=5		3/Oct	in process
2712			8	Kasumpti reservoir	added	MPN=5		3/Oct	in process

