

Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	um Thiosulph	MPN	Final report (72Hrs)	Reported on	Result
3595	20-Nov	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	P.tap ridge	added	MPN=0	–	22-Nov	Excellent
3596			2	P.tap middle bazar	added	MPN=0	–	22-Nov	Excellent
3597			3	P.tan near shiv mandir middle bazar	added	MPN=0	–	22-Nov	Excellent
3598			4	Cecil kitchen	added	MPN=25	Thermotolerant E.coli not detected by Eijkman test		UNSATISFACTORY
3599			5	Cecil storage tank	added	MPN=50	Thermotolerant E.coli not detected by Eijkman test		UNSATISFACTORY
3600			6	P.tap chaura maidan chowk	added	MPN=0	–	22-Nov	Excellent
3601			7	Sanjauli reservoir outlet	added	MPN=0	–	22-Nov	Excellent
3602			8	Kasumpti reservoir outlet	added	MPN=0	–	22-Nov	Excellent
3603	20-Nov	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank shimla	added	MPN=0	–	22-Nov	Excellent
3604			2	mainsfield tank	added	MPN=0	–	22-Nov	Excellent
3605			3	bharari tank	added	MPN=0	–	22-Nov	Excellent
3606			4	dhalli tank	added	MPN=0	–	22-Nov	Excellent
3607			5	chakkar tank	added	MPN=01	–	22-Nov	
3608			6	KNOLLSWOOD TANK	added	MPN=0	–	22-Nov	Excellent

3609			7	jakhu tank	added	MPN=0	–	22-Nov	Excellent
3610			8	kusumpati tank	added	MPN=0	–	22-Nov	Excellent
3611			9	bawari lower eid ghar colony ruldu bhatta	nil	MPN=01	–	22-Nov	
3612			10	handpump tutti kandi	nil	MPN=0	–	22-Nov	Excellent
3613			11	pub.tap near laxmi temple chotta shimla	added	MPN=0	–	22-Nov	Excellent
3614			12	pub.tap near police gumti chotta shimla	added	MPN=01	–	22-Nov	
3615	21-Nov	Samples received from Corporation	1	SANDAL CHAKKAR	added	MPN=5	Thermotolerant	23-Nov	SUSPICIOUS( not
3616			2	P.TAP HARI MANDIR CHAKKAR	added	MPN=0	–	23-Nov	excellent
3617			3	P.TAP HARI NAGAR	added	MPN=20	Thermotolerant E.coli not detected by Eijkman test	23-Nov	UNSATISFACTORY
3618			4	P.TAP JATINDER LODGE GHORA CHOWKI	added	MPN=0	–	23-Nov	excellent
3619			5	KASUMPATI RESERVOIR	added	MPN=0	–	23-Nov	excellent
3620			6	SANJAULI RESERVOIR OUTLET	added	MPN=0	–	23-Nov	excellent
3621			7	SANJAULI INLET GIRI	added	MPN=0	–	23-Nov	excellent
3622			8	SANJAULI INLET GUMMA	added	MPN=0	–	23-Nov	excellent

3623	21-Nov	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	ridge tank	added	MPN=0	–	23-Nov	excellent
3624			2	mains field tank	added	MPN=05	–	23-Nov	
3625			3	kaloston tank	added	MPN=0	–	23-Nov	excellent
3626			4	dhali tank	added	MPN=0	–	23-Nov	excellent
3627			5	tavi tank	added	MPN=0	–	23-Nov	excellent
3628			6	handpump annadale	nil	MPN=0	–	23-Nov	excellent
3629			7	jakhu tank	added	MPN=0	–	23-Nov	excellent
3630			8	pub. Tap kusumpti	added	MPN=0	–	23-Nov	excellent
3631			9	bowari near cansar hospital	nil	MPN=180+	–	23-Nov	UNSATISFACTORY
3632			10	pub. Tap middle bazaar	added	MPN=0	–	23-Nov	excellent
3633			11	pub. Tap near scandal point	added	MPN=0	–	23-Nov	excellent
3634			12	pub. Tap old post office lakkar bazaar	added	MPN=0	–	23-Nov	excellent
3635	22-Nov	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Public tap Laxmi Narayan mandir, Sanjauli	added	MPN=0	–	24-Nov	excellent
3636			2	tap water Tibetan school Dhingu	added	MPN=1			in process
3637			3	Dhingu mandir lower tank	added	MPN=0	–	24-Nov	excellent
3638			4	Dhingu mandir Sanjauli upper tank outlet	added	MPN=0	–	24-Nov	excellent

3639			5	public tap near post office Mashobra	added	MPN=0	–	24-Nov	excellent
3640			6	sanjauli reservoir outlet	added	MPN=0	–	24-Nov	excellent
3641			7	Sanjauli inlet GIRI	added	MPN=0	–	24-Nov	excellent
3642			8	Kasumpati reservoir	added	MPN=0	–	24-Nov	excellent
3643	22-Nov	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	ridge tank	added	MPN=0	–	24-Nov	excellent
3644			2	mains field tank	added	MPN=0	–	24-Nov	excellent
3645			3	bharai tank	added	MPN=0	–	24-Nov	excellent
3646			4	dhali tank	added	MPN=0	–	24-Nov	excellent
3647			5	chakkar tank	added	MPN=0	–	24-Nov	excellent
3648			6	KNOLLSWOOD TANK	added	MPN=0	–	24-Nov	excellent
3649			7	jakhu tank	added	MPN=0	–	24-Nov	excellent
3650			8	kusumpti tank	added	MPN=0	–	24-Nov	excellent
3651			9	mahamaya bowari old bus stand	added	MPN=180+	–	24-Nov	UNSATISFACTORY
3652			10	near dhali pub tap	added	MPN=0	–	24-Nov	excellent
3653			11	near apsara hotel pub. tap	added	MPN=0	–	24-Nov	excellent
3654			12	near laxmi narayan temple bowari	nil	MPN=0	–	24-Nov	excellent