

Water samples tested in Department of Microbiology IGMC, Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
847	12-May	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	P. Tap Cart road	-	added	0	-	14-May	Excellent
848			2	Kasumpatti near SDA Complex Tank	-	added	0	-	14-May	Excellent
849			3	P.Tap Below Axis Bank SDA Complex	-	added	0	-	14-May	Excellent
850			4	Kasumpatti reservior outlet	-	added	0	-	14-May	Excellent
851			5	Sanjauli reservior outlet	-	added	0	-	14-May	Excellent
852			6	Sanjauli inlet Giri	-	added	0	-	14-May	Excellent
853			7	Sanjauli Inlet Gumma	-	added	5	Esch.coli		unsatisfactory
854	13-May	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	sanjauli reservior outlet	-	added	0	-	15-May	Excellent
855			2	p. tap laxmi narain mandir sanjauli	-	added	0	-	15-May	Excellent
856			3	dhingu mandir tank lower	-	added	0	-	15-May	Excellent
857			4	dhingu mandir tank outlet upper	-	added	0	-	15-May	Excellent
858			5	supply inder nagar sanjauli	-	added	0	-	15-May	Excellent
859			6	kasumpti reservior outlet	-	added	0	-	15-May	Excellent

860	14-May	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Mains field outlet No. I	-	added	0	-	16-May	Excellent
861			2	Mains field outlet No. II	-	added	0	-	16-May	Excellent
862			3	Knollswood tank	-	added	0	-	16-May	Excellent
863			4	Public tap Khalini chowk	-	added	0	-	16-May	Excellent
864			5	Public tap Khalini Bypass	-	added	0	-	16-May	Excellent
865			6	kasumpti reserrior outlet	-	added	0	-	16-May	Excellent
866			7	sanjauli reserrior outlet	-	added	0	-	16-May	Excellent