

Water samples tested in Department of Microbiology IGMC, Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
1721	7-Aug	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	P.tap sanjauli chowk	-	added	MPN=35		9-Aug	unsatisfactory
1722			2	Mashobra tank	-	added			9-Aug	excellent
1723			3	P.tap mashobra lind	-	added	MPN=3		9-Aug	in process
1724			4	P.tap near Kapoor bhojanlaya mashobra	-	added	MPN=1		9-Aug	in process
1725			5	Tube well no 2 (uv) ashwani khad (untreated)	-	nil	MPN=180		9-Aug	unsatisfactory
1726			6	Tube well no 2 (uv) ashwani khad (treated)	-	nil	MPN=1		9-Aug	in process
1727			7	Kasumpti reservoir	-	added	MPN=1		9-Aug	in process
1728			8	Sanjauli reservoir	-	added	MPN=1		9-Aug	in process
1729	7-Aug	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	ridge tank shimla	-	added			9-Aug	excellent
1730			2	mains field tank	-	added			9-Aug	excellent
1731			3	bhari tank	-	added			9-Aug	excellent
1732			4	dhali tank	-	added			9-Aug	excellent
1733			5	tavi tank	-	added			9-Aug	excellent
1734			6	knolls wood tank	-	added			9-Aug	excellent
1735			7	Jakhu tank	-	added			9-Aug	excellent
1736			8	vikas nagar tank	-	added			9-Aug	excellent
1737			9	hand pump choulonthi	-	nil	MPN=180		9-Aug	unsatisfactory
1738			10	bowari lakkar bazaar bus stop	-	nil	MPN=30		9-Aug	unsatisfactory
1739			11	public tap water opp. Police ground bhari	-	nil			9-Aug	excellent
1740			12		-	nil			9-Aug	excellent