

Water samples tested in Department of Microbiology IGMC, Shimla

Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
1573	30-Jul	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	public tap , kasumpti bazaar, near panchyat bhawan	-	added			1-Aug	excellent
1874			2	tubewell no. 2 (uv) untreated ashwani khad	-	nil	MPN=180+			unsatisfactory
1575			3	tubewell no 2 (uv) Ashwani khad, treated water	-	nil				Excellent
1576			4	kasumpti reservoir	-	added				Excellent
1577			5	sakrala tank	-	added	MPN=1			in process
1578			6	basant vihar storage tank, rani ground	-	added				Excellent
1579			7	TTC, SSB kasumpti, main supply	-	added				Excellent
1580			8	Sanjauli reservoir	-	added				Excellent
1581	30-Jul	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank shimla	-	added			1-Aug	Excellent
1582			2	mains field tank	-	added	MPN=3		1-Aug	
1583			3	bharari tank	-	added			1-Aug	Excellent
1584			4	dhali tank	-	added			1-Aug	Excellent
1585			5	tavi tank	-	added			1-Aug	Excellent
1586			6	knolls wood tank	-	added			1-Aug	Excellent
1587			7	Jakhu tank	-	added	MPN=1		1-Aug	
1588			8	Kusumpati tank	-	added			1-Aug	Excellent
1589			9	bowari mj rooms summerhill	-	nil	MPN=180+		1-Aug	unsatisfactory
1590			10	household naveen kumar	-	nil			1-Aug	Excellent
1591			11	house hold jagdish sharma	-	nil			1-Aug	Excellent
1592			12	near MJ rooms	-	nil			1-Aug	Excellent