

Lab Sr. no	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
1849	13-04-2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Summer hill bazar tank	added	MPN=0	-	15-04-2019	Excellent
1850			2	Public tap Shiv mandir Middle bazar	added	MPN=0	-	15-04-2019	Excellent
1851			3	Kasumpati reservoir	added	MPN=5	thermotolerant E.coli not detected	16-04-2019	suspicious
1852			4	advance study steel tank	added	MPN=0	-	15-04-2019	Excellent
1853			5	public tank near Boileauganj, Shimla	added	MPN=0	-	15-04-2019	Excellent
1854			6	Boileauganj tank	added	MPN=0	-	15-04-2019	Excellent
1855			7	Sanjauli reservoir	added	MPN=5	thermotolerant E.coli not detected	16-04-2019	suspicious
1856			8	Sanjauli Gumma inlet	added	MPN=0	-	15-04-2019	Excellent
1857	13-04-2019	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank out let near shivmandir	added	MPN=0	-	15-04-2019	EXCELLENT
1858			2	Mainsfield tank	added	MPN=0	-	15-04-2019	EXCELLENT
1859			3	Pub-tap near UCO bank	added	MPN=0	-	15-04-2019	EXCELLENT
1860			4	Pub-tap near ram lal dhaba	added	MPN=0	-	15-04-2019	EXCELLENT
1861			5	Chakkar tank	added	MPN=0	-	15-04-2019	EXCELLENT
1862			6	Phase-3 tank	added	MPN=0	-	15-04-2019	EXCELLENT
1863			7	Jakhoo tank	added	MPN=0	-	15-04-2019	EXCELLENT
1864			8	Vikasnagar Tank	added	MPN=0	-	15-04-2019	EXCELLENT
1865			9	Chauhan niwas marketing board pub-tap khalini	added	MPN=0	-	15-04-2019	EXCELLENT
1866			10	Puri niwas pub-tap	added	MPN=0	-	15-04-2019	EXCELLENT
1867			11	Sood bhawan bhagwati nagar khalini	added	MPN=0	-	15-04-2019	EXCELLENT
1868			12	Guleriya house bhagwati nagar khalini	added	MPN=0	-	15-04-2019	EXCELLENT

1869	14-04-2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpati reservoir	added	MPN=0	-	16-04-2019	EXCELLENT
1870			2	Public tap Shiv mandir Middle bazar	added	MPN=0	-	16-04-2019	EXCELLENT
1871			3	Fingask tank 1	added	Mpn=1	thermotolerant E.coli not detected	17-04-2019	satisfactory
1872			4	Fingask tank 2	added	MPN=8	thermotolerant E.coli not detected	17-04-2019	suspicious
1873			5	public tap near catholic club	added	MPN=1	thermotolerant E.coli not detected	17-04-2019	satisfactory
1874			6	UTI Goel building	added	MPN=12	thermotolerant E.coli not detected	17-04-2019	unsatisfactory
1875			7	Sanjauli reservoir	added	MPN=0	-	16-04-2019	EXCELLENT
1876			8	Sanjauli Giri inlet	added	MPN=0	-	16-04-2019	EXCELLENT
1877	15-04-2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	KASUMPATI RESERVOIR	added	MPN=0	-	17-04-2019	EXCELLENT
1878			2	P.TAP NEAR SHIV MANDIR	added	MPN=0	-	17-04-2019	EXCELLENT
1879			3	P.TAP NEAR KRISHNAHILL	added	MPN=0	-	17-04-2019	EXCELLENT
1880			4	P.TAP NEAR BIHARI LAL COTTAGE	added	MPN=0	-	17-04-2019	EXCELLENT
1881			5	P.TAP NEAR LUXMI NIWAS	added	MPN=0	-	17-04-2019	EXCELLENT
1882			6	TARA HALL TANK	added	MPN=3			in process
1883			7	SANJAULI RESERVOIR	added	MPN=0	-	17-04-2019	EXCELLENT
1884			8	SANJAULI GUMMA INLET	added	MPN=0	-	17-04-2019	EXCELLENT
1885	15-04-2019	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	RIDGE TANK OUTLET NEAR SHIV MANDIR	added	MPN=0	-	17-04-2019	EXCELLENT
1886			2	MAINS FIELD TANK	added	MPN=0	-	17-04-2019	EXCELLENT
1887			3	P.TAP NEAR UCO BANK DHALLI	added	MPN=0	-	17-04-2019	EXCELLENT
1888			4	P.TAP NEAR RAM LAL DHABA DHALLI	added	MPN=0	-	17-04-2019	EXCELLENT

1889			5	Tavi tank	added	MPN=0	_	17-04-2019	EXCELLENT
1890			6	KNOWLLS WOOD OUTLET	added	MPN=1			
1891			7	JAKHOO TANK	added	MPN=0	_	17-04-2019	EXCELLENT
1892			8	VIKAS NAGAR TANK	added	MPN=0	_	17-04-2019	EXCELLENT
1893			9	YADGAR P.TAP	added	MPN=0	_	17-04-2019	EXCELLENT
1894			10	PANCHAYAT BHAWAN P.TAP	added	MPN=0	_	17-04-2019	EXCELLENT
1895			11	TOTU CHOWK P.TAP	added	MPN=0	_	17-04-2019	EXCELLENT
1896			12	P.TAP NEAR SBI ATM TOTU	added	MPN=0	_	17-04-2019	EXCELLENT