

Lab Sr. no	Date	Received through Email/Phone	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
1897	16-04-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan	1	Kasumpati reservoir	added	MPN=0	–	18-04-19	Excellent
1898			2	public tap near shiv mandir	added	MPN=0	–	18-04-19	Excellent
1899			3	public tap near bhalla niwas	added	MPN=0	–	18-04-19	Excellent
1900			4	Public tap near Police line Bharari	added	MPN=1	thermotolerant E.coli	19-04-19	satisfactory
1901			5	Bharari tank	added	MPN=0	–	18-04-19	Excellent
1902			6	Cluston tank	added	MPN=0	–	18-04-19	Excellent
1903			7	Sanjauli reservoir	added	MPN=1	thermotolerant E.coli	19-04-19	satisfactory
1904			8	Sanjauli Giri inlet	added	MPN=5	thermotolerant E.coli	19-04-19	suspicious
1905	16-04-19	Samples Received under Hepatitis Project Community Medicine IGMC	1	Ridge tank out let near shivmandir	added	MPN=0	–	18-04-19	Excellent
1906			2	Mainsfield tank	added	MPN=0	–	18-04-19	Excellent
1907			3	Pub=tap near UCO bank Dhalli	added	MPN=0	–	18-04-19	Excellent
1908			4	Pub-tap near ram lal dhaba	added	MPN=0	–	18-04-19	Excellent
1909			5	Chakkar tank	added	MPN=1			
1910			6	Phase-3 tank	added	MPN=0	–	18-04-19	Excellent
1911			7	Jakhoo tank	added	MPN=0	–	18-04-19	Excellent
1912			8	Vikasnagar Tank	added	MPN=0	–	18-04-19	Excellent
1913			9	Pub-tap near old brock host Chotta Shimla	added	MPN=1			
1914			10	Pub-tap near Apna Medical store	added	MPN=0	–	18-04-19	Excellent
1915			11	Pub-tap Police gumti Chotta Shimla	added	MPN=0	–	18-04-19	Excellent

1916			12	Pub-tap near Lift Mall road	added	MPN=0	–	18-04-19	Excellent
1917	17-04-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan	1	Kasumpati reservoir	added	MPN=0	–	19-04-19	Excellent
1918			2	P.tap near shiv mandir middle bazar	added	MPN=14	thermotolerant E.coli not	20-04-19	unsatisfactory
1919			3	Sanjauli reservoir	added	MPN=0	–	19-04-19	Excellent
1920			4	Sanjauli Gumma inlet	added	MPN=180	thermotolerant E.coli	20-04-19	unsatisfactory
1921			5	North oak UG tank	added	MPN=1	thermotolerant E.coli	20-04-19	SATISFACTORY
1922			6	North oak OH tank	added	MPN=0	–	19-04-19	Excellent
1923			7	Housing board colony tank no 1	added	MPN=0	–	19-04-19	Excellent
1924			8	Housing board colony tank no 2	added	MPN=18	thermotolerant E.coli	20-04-19	unsatisfactory
1925	17-04-19	Samples Received under Hepatitis Project Community Medicine IGMC	1	Ridge tank out let near shivmandir	added	MPN=0	–	19-04-19	Excellent
1926			2	Mainsfield tank	added	MPN=0	–	19-04-19	Excellent
1927			3	Near police station pub-tap lakkar bazar	added	MPN=180+			unsatisfactory
1928			4	DHALLI TANK	added	MPN=180+			unsatisfactory
1929			5	TAVI TANK	added	MPN=0	–	19-04-19	Excellent
1930			6	Knollswood tank outlet nerar sood bhawan	added	MPN=1			
1931			7	Halliloge pub-tap	added	MPN=180+			unsatisfactory
1932			8	Vikasnagar Tank	added	MPN=0	–	19-04-19	Excellent
1933			9	Pub-tap near CTO The mall	added	MPN=1			
1934			10	Pub tap near Lift Mall road	added	MPN=1			in process
1935			11	Pub tap lakkar bazar near durga temple	added	MPN=0	–	19-04-19	Excellent
1936			12	Pub tap ganj bazar	added	MPN1			