

Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
3413	08-Jul-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	KASUMPATI RESERVOIR	added	MPN = 1	thermotolerant E.coli not detected	11-07-19	SATISFACTORY
3414			2	KNOLLSWOOD TANK	added	MPN=0	—	10-07-19	excellent
3415			3	P.TAP NEAR KHALINI CHOWK	added	MPN=13	thermotolerant E.coli not detected	11-07-19	unsatisfactory
3416			4	P.TAP NEAR PANCHI AHTA	added	MPN =6	thermotolerant E.coli not detected	11-07-19	suspicious
3417			5	SUPPLY NEAR SOOD BHAWAN JHANJHIRI	added	MPN =20	thermotolerant E.coli not detected	11-07-19	unsatisfactory
3418			6	SUPPLY NEAR GULERIA NIWAS BHAGWATI	added	MPN= 0	—	10-07-19	excellent
3419			7	P.TAP NEAR BIHARI LAL COTTAGE ANNADALE	added	MPN =3	thermotolerant E.coli not detected	11-07-19	SATISFACTORY
3420			8	SANJAULI RESERVOIR	added	MPN =1	thermotolerant E.coli not detected	11-07-19	SATISFACTORY
3421	08-07-19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge pub-tap HPMC	added	MPN=2			
3422			2	mains field tank	added	MPN= 0	—	10-07-19	excellent
3423			3	Kalaston Tank	added	MPN=9			
3424			4	Dhali tank	added	MPN=7			
3425			5	Pub tap near PNB totu	added	MPN=17			unsatisfactory
3426			6	Knowllows wood tank	added	MPN= 0	—	10-07-19	excellent
3427			7	Jakhu tank ropeway	added	MPN= 0		10-07-19	excellent
3428			8	Pub-tap Brock host chotta Shimla	added	MPN=7			
3429			9	Pub-tap near RCC	added	MPN=2			
3430			10	Pub-tap charley mount	added	MPN= 0	—	10-07-19	excellent
3431			11	Pub-tap near holly lodge	added	MPN=2			
3432			12	Pub-tap dhalpur house	added	MPN=3			

3433	09-07-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpati reservoir	added	MPN= 0	–	11-Jul-19	EXCELLENT
3434			2	Jakhu tank near Hanuman temple	added	MPN= 0	–	11-Jul-19	EXCELLENT
3435			3	Jakhu tank UG near	added	MPN=3			in process
3436			4	Jakhu water ATM	added	MPN=0	–	11-Jul-19	EXCELLENT
3437			5	public tap near Kalimata mandir, Bhagvati nagar	added	MPN=5			in process
3438			6	Sanjauli reservoir	added	MPN= 0	–	11-Jul-19	EXCELLENT
3439			7	Public tap near old police thana sanjauli	added	MPN=1			in process
3440			8	Dhingu tank outlet	added	MPN=1			in process
3441	09-07-19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN= 0	–	11-Jul-19	EXCELLENT
3442			2	mains field tank	added	MPN= 0	–	11-Jul-19	EXCELLENT
3443			3	pub-tap rl dhaba dhalli	added	MPN= 0	–	11-Jul-19	EXCELLENT
3444			4	Dhali tank	added	MPN= 0	–	11-Jul-19	EXCELLENT
3445			5	Pub-tap fullu bhawan	added	MPN= 0	–	11-Jul-19	EXCELLENT
3446			6	Phase-3 tank	added	MPN= 0	–	11-Jul-19	EXCELLENT
3447			7	Jakhu tank ropeway	added	MPN= 0	–	11-Jul-19	EXCELLENT
3448			8	Pub-tap sood bhawan bhagwati nagar	added	MPN= 0	–	11-Jul-19	EXCELLENT
3449			9	Pub-tap Police gumti Chotta Shimla	added	MPN= 0	–	11-Jul-19	EXCELLENT
3450			10	Pub-tap apna medical store chotta Shimla	added	MPN= 0	–	11-Jul-19	EXCELLENT