Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
3601	18/07/2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpti Reservoir(Repeat)	added	MPN=11	thermotolerant E.coli not detected	21/7/19	unsatisfactory
3602			2	Public tap near Preet hotel (Repeat)	added	MPN=1	thermotolerant E.coli not detected	21/7/19	satisfactory
3603			3	Public tap near Tibetian colony(Repeat)	added	MPN=1	thermotolerant E.coli not detected	21/7/19	satisfactory
3604			4	public tap near Gopal jee Ganj bazar(Repeat)	added	MPN=1	thermotolerant E.coli not detected	21/7/19	satisfactory
3605			5	public tap near Khadi bandhar,Mall road Shimla(Repeat)	added	MPN=2	thermotolerant E.coli not detected	21/7/19	satisfactory
3606			6	public tap near Samsung shop,Mall road(Repeat)	added	MPN = 0	_	20/07/2019	EXCELLENT
3607			7	public tap near HPMC Ridge(Repeat)	added	MPN = 0	_	20/07/2019	EXCELLENT
3608			8	Sanjauli reservoir(Repeat)	added	MPN = 0	_	20/07/2019	EXCELLENT
3609	18-07-19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge pub-tap near HPMC	added	MPN=1			
3610			2	mains field tank	added	MPN=14			
3611			3	Bharari tank	added	MPN=20			
3612			4	Dhalli tank	added	MPN=5			
3613			5	Tavi tank	added	MPN=180			Unstisfactory
3614			6	Phase-3 tank	added	MPN=3			
3615			7	Jakhu tank ropeway	added	MPN=20			
3616			8	Vikasnagar Tank	added	MPN=10			
3617			9	Pub-tap police line bharari	added	MPN=180+			unstisfactory
3618			10	Pub-tap cow shade krishnanger	added	MPN=9			
3619			11	Pub-tap Gaddi khana krishna nagar	added	MPN=3			
3620			12	Pub tap gaddi khana krishna nagar-2	added	MPN=4			