

Lab Sr. n	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
4229	23/8/19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpti Reservoir	added	MPN=0	<b>thermotolerant E.coli not detected</b>	26-08-2019	excellent
4230			2	Aqua guard HP secteriat New building First floor	nil	MPN=0	<b>thermotolerant E.coli not detected</b>	26-08-2019	excellent
4231			3	Aquaguard HP secteriat, new building, second floor	nil	MPN=0	<b>thermotolerant E.coli not detected</b>	26-08-2019	excellent
4232			4	Aquaguard HP secteriat, new building, thrid floor	nil	MPN=0	<b>thermotolerant E.coli not detected</b>	26-08-2019	excellent
4233			5	Aquaguard HP secteriat, new building, fourth floor	added	MPN=0	<b>thermotolerant E.coli not detected</b>	26-08-2019	excellent
4234			6	Aquaguard HP secteriat, new building, sixth floor	added	MPN=0	<b>thermotolerant E.coli not detected</b>	26-08-2019	excellent
4235			7	Aquaguard HP secteriat, new building, Ground floor canteen	added	MPN=6	<b>thermotolerant E.coli not detected</b>	26-08-2019	Adv: Repeat sample requested
4236			8	Sanjauli reservoir	added	MPN=0	<b>thermotolerant E.coli not detected</b>	26-08-2019	excellent
4237	23-08-2019	<b>Samples Received under Hepatitis Project Community Medicine IGMC Shimla</b>	1	Ridge tank	added	MPN=0		25-08-2019	EXCELLENT
4238			2	Public tap Ridge HPMC	added	MPN=0		25-08-2019	EXCELLENT
4239			3	Kelaston tank	added	MPN=0		25-08-2019	EXCELLENT

4240			4	Dhali tank	added	MPN=0		25-08-2019	EXCELLENT
4241			5	Public tap Dhanda chowk	added	MPN=1		25-08-2019	
4242			6	public tap Dhanda near SBI ATM	added	MPN=0		25-08-2019	EXCELLENT
4243			7	Jakhu ropeway tank	added	MPN=1		25-08-2019	
4244			8	Public tap Kasumpti near PNB ATM	added	MPN=0		25-08-2019	EXCELLENT
4245			9	Public tap near Kamal Bhawan	added	MPN=0		25-08-2019	EXCELLENT
4246			10	Public tap Fullu bhawan	added	MPN=0		25-08-2019	EXCELLENT
4247			11	public tap Totu chowk	added	MPN=0		25-08-2019	EXCELLENT
4248			12	Public tap near SBI ATM Totu	added	MPN=0		25-08-2019	EXCELLENT
4249	24-08-2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpti Reservoir	added	MPN=0	<b>thermotolerant E.coli not detected</b>	27-08-2019	EXCELLENT
4250			2	Supply near YASH COTTAGE VIKAS NAGAR(Repeat)	added	MPN=0	<b>thermotolerant E.coli not detected</b>	27-08-2019	EXCELLENT
4251			3	Public tap near M.C. office New Shimla	added	MPN=0	<b>thermotolerant E.coli not detected</b>	27-08-2019	EXCELLENT
4252			4	Sector-I tank	added	MPN=0	<b>thermotolerant E.coli not detected</b>	27-08-2019	EXCELLENT
4253			5	Tara mata mandir tank	added	MPN=0	<b>thermotolerant E.coli not detected</b>	27-08-2019	EXCELLENT
4254			6	Phase-III tank-I near Police thana	added	MPN=0	<b>thermotolerant E.coli not detected</b>	27-08-2019	EXCELLENT
4255			7	Phase-III tank 2 near block-6&7	added	MPN=0	<b>thermotolerant E.coli not detected</b>	27-08-2019	EXCELLENT
4256			8	Sanjauli reservoir	added	MPN=0	<b>thermotolerant E.coli not detected</b>	27-08-2019	EXCELLENT

4257	24-08-2019	<b>Samples Received under Hepatitis Project Community Medicine IGMC Shimla</b>	1	Public tap HPMC Ridge	added	MPN=0		26-08-2019	EXCELLENT
4258			2	Public tap Servant quarter Ridge	added	MPN=0		26-08-2019	EXCELLENT
4259			3	Public tap UCO bank Dhalli	added	MPN=1		26-08-2019	
4260			4	Dhalli tank	added	MPN=5		26-08-2019	
4261			5	Public tap green valley	added	MPN=0		26-08-2019	EXCELLENT
4262			6	Knollswood tank	added	MPN=0		26-08-2019	EXCELLENT
4263			7	Public tap near SBI Sanjauli	added	MPN=0		26-08-2019	EXCELLENT
4264			8	VIKASNAGAR TANK	added	MPN=1		26-08-2019	
4265			9	Public tap Kanlog	added	MPN=180+		26-08-2019	Unsatisfactory
4266			10	Public tap Shiv puri	added	MPN=6		26-08-2019	
4267			11	Public tap SDA complex	added	MPN=1		26-08-2019	
4268			12	Public tap Sanjauli	added	MPN=1		26-08-2019	
4269	25-08-2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpti Reservoir	added	MPN=0	thermotolerant E.coli not detected	28/8/19	excellent
4270			2	Public tap near Titla Hotel Jakhu	added	MPN=0	thermotolerant E.coli not detected	28/8/19	excellent
4271			3	Supply near Lahnu Bhawan Jakhu	added	MPN=0	thermotolerant E.coli not detected	28/8/19	excellent
4272			4	Public tap near Holly lodge	added	MPN=0	thermotolerant E.coli not detected	28/8/19	excellent
4273			5	Public tap near Dholpur house Jakhu	added	MPN=0	thermotolerant E.coli not detected	28/8/19	excellent
4274			6	Jakhu tank No. I near ropeway	added	MPN=0	thermotolerant E.coli not detected	28/8/19	excellent

4275			7	Jakhu tank No. II near Hanuman mandir	added	MPN=0	thermotolerant E.coli not detected	28/8/19	excellent
4276			8	Sanjauli reservoir	added	MPN=0	thermotolerant E.coli not detected	28/8/19	excellent