

Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
3925	5/8/2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpati reservoir	added	MPN = 14	thermotolerant E.coli not detected	8/8/2019	UNSATISFACTORY
3926			2	public tap near Preet hotel(repeat)	added	MPN =2	thermotolerant E.coli not detected	8/8/2019	SATISFACTORY
3927			3	public tap near Samsung shop Mall road(repeat)	added	MPN =10	thermotolerant E.coli not detected	8/8/2019	SUSPICIOUS
3928			4	North Oak UG TANK	added	MPN = 180+	thermotolerant E.coli not detected	8/8/2019	Adv : Repeat sample
3929			5	North Oak O.H. TANK	added	MPN = 13	thermotolerant E.coli not detected	8/8/2019	Adv : Repeat sample
3930			6	Public tap near Laxmi narayan temple	added	MPN =90	thermotolerant E.coli not detected	8/8/2019	Adv : Repeat sample
3931			7	Public tap near old police thana sanjauli	added	MPN = 40	thermotolerant E.coli not detected	8/8/2019	Adv : Repeat sample
3932			8	Sanjauli reservoir	added	MPN =17	thermotolerant E.coli not detected	8/8/2019	UNSATISFACTORY
3933	5/8/2019	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=1		7/8/2019	
3934			2	Mains field tank	added	MPN=1		7/8/2019	
3935			3	Pub-tap police line bharari	added	MPN=1		7/8/2019	
3936			4	DHALLI TANK	added	MPN=0		7/8/2019	EXCELLENT
3937			5	Tavi tank	added	MPN=0		7/8/2019	EXCELLENT
3938			6	Phase-3 tank	added	MPN=2		7/8/2019	
3939			7	Jakhoo tank rope way	added	MPN=1		7/8/2019	
3940			8	Pub-tap near Police gumti Chotta Shimla	added	MPN=0		7/8/2019	EXCELLENT
3941			9	Pub-tap dhalpur house	added	MPN=3		7/8/2019	
3942			10	Pub-tap baba balak nath jakhu	added	MPN=1		7/8/2019	
3943			11	Pub-tap five banch jakhu	added	MPN=2		7/8/2019	
3944			12	Pub-tap rope way jakhu	added	MPN=0		7/8/2019	EXCELLENT

3945	6-Aug-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	KASUMPATI RESERVOIR	added	MPN=0	thermotolerant E.coli not detected	9/8/2019	EXCELLENT
3946			2	P.TAP NEAR MC OFFICE NEW SHIMLA	added	MPN=0	thermotolerant E.coli not detected	9/8/2019	EXCELLENT
3947			3	P.TAP NEAR DAV NEW SHIMLA	added	MPN=0	thermotolerant E.coli not detected	9/8/2019	EXCELLENT
3948			4	SECTOR - I TANK	added	MPN=1	thermotolerant E.coli not detected	9/8/2019	satisfactory
3949			5	TARA MATA MANDIR TANK	added	MPN=0	thermotolerant E.coli not detected	9/8/2019	EXCELLENT
3950			6	PHASE - III TANK NO.-1	added	MPN=1	thermotolerant E.coli not detected	9/8/2019	satisfactory
3951			7	PHASE - III TANK NO.-3 NEAR BLOCK 6&7	added	MPN=1	thermotolerant E.coli not detected	9/8/2019	satisfactory
3952			8	SANAJAULI RESERVOIR	added	MPN=0	thermotolerant E.coli not detected	9/8/2019	EXCELLENT
3953	6-Aug-19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=0		8/8/2019	EXCELLENT
3954			2	Mainsfield tank	added	MPN=0		8/8/2019	EXCELLENT
3955			3	Kelaston tank	added	MPN=0		8/8/2019	EXCELLENT
3956			4	DHALLI TANK	added	MPN=0		8/8/2019	EXCELLENT
3957			5	Pub-tap totu chowk	added	MPN=0		8/8/2019	EXCELLENT
3958			6	Knollswood tank	added	MPN=0		8/8/2019	EXCELLENT
3959			7	Jakhoo tank rope way	added	MPN=0		8/8/2019	EXCELLENT
3960			8	Pub-tap chintpurni chowk Khalini upper	added	MPN=1		8/8/2019	
3961			9	Pub-tap near chintpurni chowk khalini	added	MPN=0		8/8/2019	excellent
3962			10	Pub-tap near hanuman mandir khalini	added	MPN=0		8/8/2019	excellent
3963			11	Pub-tap punchiahta khalini -1	added	MPN=1		8/8/2019	
3964			12	Pub-tap punchiahta khalini-2	added	MPN=0		8/8/2019	excellent