

Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
4701	18-9-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpti reservoir	added	MPN=0	thermotolerant E.coli not detected	21/9/19	EXCELLENT
4702			2	Water ATM Jakhu	added	MPN=0	thermotolerant E.coli not detected	21/9/19	EXCELLENT
4703			3	Jakhu tank near ropeway	added	MPN=0	thermotolerant E.coli not detected	21/9/19	EXCELLENT
4704			4	jakhu tank no. 2 , near Hanuman temple	added	MPN=1	thermotolerant E.coli not detected	21/9/19	SATisfactory
4705			5	P.Tap near holly lodge, jakhu	added	MPN=0	thermotolerant E.coli not detected	21/9/19	EXCELLENT
4706			6	Supply near Lahnu Bhawan Jakhu	added	MPN=1	thermotolerant E.coli not detected	21/9/19	Satisfactory
4707			7	P.tap near charlie mount	added	MPN=0	thermotolerant E.coli not detected	21/9/19	EXCELLENT
4708			8	Sanjauli reservoir	added	MPN=0	thermotolerant E.coli not detected	21/9/19	EXCELLENT
4709	18/9/19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=0		20/9/19	EXCELLENT
4710			2	mains field tank	added	MPN=1		20/9/19	
4711			3	Kalaston Tank	added	MPN=0		20/9/19	EXCELLENT
4712			4	Dhali tank	added	MPN=1		20/9/19	
4713			5	Chakkar tank	added	MPN=1		20/9/19	
4714			6	Knollswood tank	added	MPN=0		20/9/19	EXCELLENT

4715			7	Jakhoo tank roway	added	MPN=1		20/9/19	
4716			8	Pub-tap brock hurst chotta shimla	added	MPN=1		20/9/19	
4717			9	Pub-tap suji lane gunj	added	MPN=2		20/9/19	
4718			10	Pub-tap babakhan store	added	MPN=5		20/9/19	
4719			11	Pub-tap purshartha basti	added	MPN=0		20/9/19	EXCELLENT
4720			12	Pub-tap indira chowk	added	MPN=0		20/9/19	EXCELLENT
4721	19/9/19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	KASUMPATI RESERVOIR	added	MPN =3	thermotolerant E.coli not detected	22/9/19	SATISFACTORY
4722			2	P.TAP NEAR CHADA TRANSPORT NEAR GURUDWARA	added	MPN =18	thermotolerant E.coli not detected	22/9/19	UNSATISFACTORY. Adv: Repeat sample
4723			3	P.TAP NEAR GADDI KHANA	added	MPN =4	thermotolerant E.coli not detected	22/9/19	SUSPICIOUS. Adv: repeat sample
4724			4	P.TAP NEAR COW SHED	added	MPN =0	thermotolerant E.coli not detected	22/9/19	EXCELLENT
4725			5	P.TAP NEAR COUNCILLOR HOUSE RULDUBHATA	added	MPN =0	thermotolerant E.coli not detected	22/9/19	EXCELLENT
4726			6	P.TAP NEAR SHYAM SINGH BUILDING RULDUBHATA	added	MPN =5	thermotolerant E.coli not detected	22/9/19	SUSPICIOUS. Adv: Repeat sample
4727			7	P.TAP NEAR 12 HOUSE LINE RULDUBHATA	added	MPN =0	thermotolerant E.coli not detected	22/9/19	EXCELLENT
4728			8	SANJAULI RESERVOIR	added	MPN =2	thermotolerant E.coli not detected	22/9/19	SATISFACTORY
4729	19/9/19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=0		21/9/19	EXCELLENT
4730			2	mains field tank	added	MPN=0		21/9/19	EXCELLENT
4731			3	Pub-tap near SBI sanjauli	added	MPN=0		21/9/19	EXCELLENT
4732			4	Dhali tank	added	MPN=3		21/9/19	
4733			5	Pub-tap dhanda	added	MPN=180+		21/9/19	UNsatisfactory
4734			6	Phase-3 tank	added	MPN=0		21/9/19	EXCELLENT

4735			7	Jakhoo tank ropeway	added	MPN=0		21/9/19	EXCELLENT
4736			8	Pub-tap apna medical store chotta Shimla	added	MPN=180+		21/9/19	UNsatisfactory
4737			9	Pub-tap cow shade -2	added	MPN=1		21/9/19	
4738			10	Pub-tap gaddi khana	added	MPN=30		21/9/19	UNsatisfactory
4739			11	Pub-tap near ambadker bhawan	added	MPN=0		21/9/19	EXCELLENT
4740			12	Pub-tap near chadda transport	added	MPN=1		21/9/19	