

Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
4849	26/9/19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	KASUMPATI RESERVOIR	added	MPN=0	thermotolerant E.coli not detected	29/9/19	in process
4850			2	P.TAP NEAR EVA SALE CORP GANJ BAZAR	added	MPN=0	thermotolerant E.coli not detected	29/9/19	in process
4851			3	P. TAP NEAR PRUSHARTHI BASTI LOWER BAZAR	added	MPN=1	thermotolerant E.coli not detected	29/9/19	Satisfactory
4852			4	P.TAP NEAR SUNDER DASS SHOPELOWER BAZAR	added	MPN=0	thermotolerant E.coli not detected	29/9/19	in process
4853			5	P.TAP NEAR SABJI MANDI LOWER BAZAR	added	MPN=0	thermotolerant E.coli not detected	29/9/19	in process
4854			6	P. TAP NEAR INDERA CHOWK LOWER BAZAR	added	MPN=0	thermotolerant E.coli not detected	29/9/19	in process
4855			7	P.TAP NEAR KHADI BHANDAR MALL ROAD	added	MPN=0	thermotolerant E.coli not detected	29/9/19	in process
4856			8	SANJAULI RESERVOIR	added	MPN=0	thermotolerant E.coli not detected	29/9/19	in process
4857	26/9/19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=2		28/9/19	
4858			2	Mainsfield tank	added	MPN=12		28/9/19	unsatisfactory
4859			3	Kelaston tank	added	MPN=3		28/9/19	
4860			4	Dhalli tank	added	MPN=1		28/9/19	
4861			5	Pub-tap Dhanda chowk	added	MPN=180+		28/9/19	unsatisfactory
4862			6	Pubtap SBI sanjauli	added	MPN=3		28/9/19	
4863			7	Jakhoo tank ropeway	added	MPN=2		28/9/19	
4864			8	Pub-tap brock hurst chotta shimla	added	MPN=180+		28/9/19	unsatisfactory
4865			9	bharai tank	added	MPN=180		28/9/19	unsatisfactory
4866			10	Pub-tap Police line bharari	added	MPN=2		28/9/19	
4867			11	Pub-tap bhalla niwas bharari	added	MPN=2		28/9/19	
4868			12	Pub-tap police quarter bharari	added	MPN=1		28/9/19	

4869	27/09/2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpti reservoir	added	MPN=30	thermotolerant E.coli not detected	30/9/19	UNSATISFACTORY
4870			2	SDA Kasumpti tank(repeat)	added	MPN=5	thermotolerant E.coli not detected	30/9/19	SUSPICIOUS
4871			3	Public tap near Durga cottage (repeat)	added	MPN=0	thermotolerant E.coli not detected	30/9/19	EXCELLENT
4872			4	Public tap near Police Gumati Chotta Shimla	added	MPN=0	thermotolerant E.coli not detected	30/9/19	EXCELLENT
4873			5	Public tap near servant quarters Knolls wood	added	MPN=0	thermotolerant E.coli not detected	30/9/19	EXCELLENT
4874			6	Knolls wood tank(repeat)	added	MPN=50	thermotolerant E.coli not detected	30/9/19	UNSATISFACTORY
4875			7	Mains field tank(repeat)	added	MPN=0	thermotolerant E.coli not detected	30/9/19	EXCELLENT
4876			8	Sanjauli reservoir	added	MPN=0	thermotolerant E.coli not detected	30/9/19	EXCELLENT
4877	27/9/19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=2		29/9/19	
4878			2	Pub-tap Ridge HPMC	added	MPN=5		29/9/19	
4879			3	bharai tank	added	MPN=0		29/9/19	EXCELLENT
4880			4	DHALLI TANK	added	MPN=3		29/9/19	
4881			5	TAVI TANK	added	MPN=1		29/9/19	
4882			6	Chakkar tank	added	MPN=2		29/9/19	
4883			7	Jakhoo tank ropeway	added	MPN=0		29/9/19	EXCELLENT
4884			8	Pub-tap near Apna Medical store Chotta Shimla	added	MPN=7		29/9/19	
4885			9	Pub-tap dhanda near SBI ATM	added	MPN=180+		29/9/19	unsatisfactory
4886			10	Pub-tap near kamal bhawan dhanda	added	MPN=50		29/9/19	unsatisfactory
4887			11	Pub-tap near fullu bhawan dhanda	added	MPN=9		29/9/19	
4888			12	Pub-tap green valley	added	MPN=5		29/9/19	