

RESULTS OF BACTERIOLOGICAL SAMPLES RECEIVED ON DATED 26-10-2020

Sr. No.	Collection Date	Lab. Code	Location of Sample taken	ANALYSIS RESULTS		Final Reporting Date
				Total Coliform MPN/100 ml	E.Coli MPN/100 ml	
1	26.10.2020	641	Kasumpti Reservoir	<1.1	not required	29.10.2020
2		642	P.Tap Near MC Office Shimla	<1.1	not required	29.10.2020
3		643	Set 3 Old Tank	>23	9.2	29.10.2020
4		644	P.Tap Near kranti chowk	<1.1	not required	29.10.2020
5		645	Set 3 New Tank	<1.1	not required	29.10.2020
6		646	P.Tap near mangla Bhawan	<1.1	not required	29.10.2020
7		647	Tara mata mandir Tank	<1.1	not required	29.10.2020
8		648	Knallswood Tank	<1.1	not required	29.10.2020
9		649	Mainsfield Tank	<1.1	not required	29.10.2020
10		650	Bhimakali Tank (Reservoir)	<1.1	not required	29.10.2020
11		651	P.Tap Near Hari Mandir, Chakkar	<1.1	not required	29.10.2020
12		652	Phagli Tank	<1.1	not required	29.10.2020
13		653	P.Tap near councillor house Ruldobhatta	<1.1	not required	29.10.2020
14		654	P.Tap near shiv cottage Ruldobhatta	<1.1	not required	29.10.2020
15		655	Bharari Tank	<1.1	not required	29.10.2020
16		656	Sanjauli Reservoir	<1.1	not required	29.10.2020
17		657	Giri Inlet	<1.1	not required	29.10.2020
18		658	Gumma Inlet	<1.1	not required	29.10.2020
19		659	P.Tap Near Dhalli Chowk	<1.1	not required	29.10.2020
20		660	Dhalli Tank Outlet	<1.1	not required	29.10.2020